

APPENDIX A. SUBSTATION EQUIPMENT DATABASE

Equipment Type	Voltage (kV)	Manufacturer	Model	Qualification Procedure	Report Date	Horizontal Qualification Level (g)	Vertical Qualification Level (g)	Spectrum	X Maximum Displacement (inch)	Y Maximum Displacement (inch)	Z Maximum Displacement (inch)	Fundamental Frequency (Hz)	Direction/ Mode	Other Natural Frequency (Hz)	Direction/ Mode	Damping ratio (%)	First modal participation factor	Total Mass (kg)	Modal Mass (kg)	Contributor	Notes
Bushing (1)a	550	ABB	550X2000 UW									8.2	X-Dir			4	-	3740	-	PEER	
Bushing (1)b	550	ABB	550X2000 UW									7.9	Y-Dir			4	-	3740	-	PEER	
Bushing (2)a	550	ABB	550SEIS20 00-1									8	X-Dir			4	-	3740	-	PEER	
Bushing (2)b	550	ABB	550SEIS20 00-1									8.2	Y-Dir			4	-	3740	-	PEER	
Bushing (3)a	550	ABB	550SEIS20 00-1									8	X-Dir			4	-	3740	-	PEER	
Bushing (3)b	550	ABB	550SEIS20 00-1									7.8	Y-Dir			4	-	3740	-	PEER	
Bushing (1)a	230	GE	Serial # 1795450 3000-A, type U									20	X-Dir			2	-	920	-	PEER	Test Set 1-6; Effective modal weight depends on test performed.
Bushing (1)b	230	GE	Serial # 1795450 3000-A, type U									18	Y-Dir			2	-	920	-	PEER	Test Set 1-6; Effective modal weight depends on test performed.
Bushing (2)a	230	GE	Serial # 1795451 3000-A, type U									20	X-Dir			3	-	920	-	PEER	Test Set 18-20; Effective modal weight depends on test performed.
Bushing (2)b	230	GE	Serial # 1795450 3000-A, type U									18	Y-Dir			2	-	920	-	PEER	Test Set 18-20; Effective modal weight depends on test performed.
Bushing (3)a	230	GE	Serial # 1795451 3000-A, type U									20	X-Dir			3	-	920	-	PEER	Test Set 1, 12-16; Effective modal weight depends on test performed.
Bushing (3)b	230	GE	Serial # 1795451 3000-A, type U									18	Y-Dir			2	-	920	-	PEER	Test Set 1, 12-16; Effective modal weight depends on test performed.
Bushing (2)a	230	GE	Serial # 1795451 3000-A, type U									20	X-Dir			3	-	920	-	PEER	Test Set 26-28; Effective modal weight depends on test performed.
Bushing (2)b	230	GE	Serial # 1795451 3000-A, type U									18	Y-Dir			2	-	920	-	PEER	Test Set 26-28; Effective modal weight depends on test performed.
Bushing (2)a	230	GE	Serial # 1795451 3000-A, type U									14*	X-Dir			3	-	920	-	PEER	Test Set 31-33; a second mode frequency of 26.5 Hz was evident in both directions


Bushing: Transformer	230	Haeßly Trench	Time History	01-Jul-96	1	0.8	IEEE 693-97 Draft High	0.46		5.3	1st	25.6	2nd	4.5	838	Rulon-Frank	Composite
Bushing: Transformer	230	Haeßly Trench	Sine Beat	01-Jul-96	1	0.8	IEEE 693-97 Draft High	1.26		5.3	1st	25.6	2nd	4.5	838	Rulon-Frank	Composite
Bushing: Transformer	500	Haeßly Trench	Time History	01-Jul-96	1	0.8	IEEE 693-97 Draft High	2.44		3.9	1st	20.7	2nd	6	1832	Rulon-Frank	Composite
Bushing: Transformer	500	Haeßly Trench	Sine Beat	01-Jul-96	1	0.8	IEEE 693-97 Draft High	4.46		3.9	1st	20.7	2nd	6	1832	Rulon-Frank	Composite
Bushing: Transformer	196	GEC Alsthom	Time History	03-Nov-97	1	0.8	IEEE 693-97 Draft High									Rulon-Frank	No contact, Test plan only, No test info.
Bushing: Transformer	196	Reynolle Ltd	Sin beat	19-Mar-98	1	0.8	IEEE 693-97 High	20 mm		8.6	X Axis	10	Y Dir	2	380	Rulon-Frank	
Bushing: Transformer	196	Reynolle Ltd	Time History	19-Mar-98	1	0.8	IEEE 693-97 High	12 mm		8.6	X Axis	10	Y Dir	2	380	Rulon-Frank	
Bushing: DC (Spares)	500	ABB	Sine Beat	05-Oct-98	1	0.8	IEEE 693-97 High									Rulon-Frank	Tested as Spare; Supported top and bottom
Bushing: DC (Spares)	500		Time History		1	0.8	IEEE 693-97 High									Rulon-Frank	Tested as Spare; Supported top and bottom
Bushing	230	HSP Hochspannungsgerate	Time History	19-Jul-00	1	0.8	IEEE 693-97 High	1.18		9.8	1st			2	90.7	Rulon-Frank	Composite Insulator, Transformer support
Bypass Breaker	595	GEC Alsthom	Dynamic Analysis	01-Jul-94	0.2	0.16	LADWP Spectra	0.6	0.6	3.2	X Axis	3.2	Y Axis	2	1327	Rulon-Frank	Steel frame
Capacitor: Shunt			Dynamic Analysis	01-Feb-98	0.4	0.32	IEEE 693	0.69	0.86	4.32	Y Axis			2*		PG+E	Welded Aluminum Frame
Capacitor: Shunt			Dynamic Analysis	01-Feb-98	0.4	0.32	IEEE 693	0.36	0.46	6.36	Y Axis			2*		PG+E	Welded Aluminum Frame
Capacitor: Shunt			Dynamic Analysis	01-Feb-98	0.4	0.32	IEEE 693	0.4	0.5	6.08	Y Axis			2*		PG+E	Welded Aluminum Frame
Capacitor: Shunt			Dynamic Analysis	01-Jan-97	0.4	0.27	IEEE 693	0.25	0.98	2.2	X Axis			2*		PG+E	Welded aluminum frame
Capacitor: Shunt			Dynamic Analysis	01-Oct-98	0.4		IEEE 693-1997	1.38		3.71	1st Res Freq			2*		PG+E	Aluminum structure
Capacitor: Shunt			Dynamic Analysis	01-Dec-98	0.4		IEEE 693-1997	1.68		2.78	1st Res Freq			2*		PG+E	
Capacitor: Shunt			Dynamic Analysis	01-Nov-98	0.4		IEEE 693-1997	1.43		3.71	1st Res Freq			2*		PG+E	Aluminum Structure
Capacitor: Shunt			Dynamic Analysis	01-Oct-98	0.4		IEEE 693-1997	1.13		4.06	1st Res Freq			2*		PG+E	Aluminum Structure
Capacitor: Shunt			Static Analysis	01-Mar-97	0.2		Static	0.7	0.01					2*		PG+E	Aluminum Frame
Capacitor: Shunt			Dynamic Analysis	01-Feb-98	0.4	0.32	IEEE 693	0.92	1.06	3.95	Y Axis			2*		PG+E	Welded Aluminum Frame
Capacitor: Shunt			Dynamic Analysis	01-Feb-98	0.4	0.32	IEEE 693	0.55	0.67	5.08	Y Axis			2*		PG+E	Welded Aluminum Frame

Current Transducers	500	ABB		Time History	10-Feb-99	1	0.8	IEEE 693-97 Draft High	0.79	0.79	0.08	2.3	X Axis	2.5	Y Dir	3.5	1930	Rubio-Frank	Guyed, Porcelain support, Polymer bracing, 9.71 cm tall support bracket
Current Transducers	500	Riz		Sine Beat	31-Mar-97	0.5	0	IEEE 693-97 Draft High	4.96	6.61		2.9	X Axis	2.16	Y Dir	6.5		Rubio-Frank	
Disconnect Switch	765	Contact Hydo-Quebec	682-PE-0112-A BCVB									0.87 o 1.20 f				5	0.89 refo 0.80 maco 1.39 rof 1.25 msec/f	Hydo-Quebec	Frame Type
Disconnect Switch	500	Contact Hydo-Quebec	682-PE-0112-A BCVB									1.15 o 1.66 f				2*	0.88 refo 0.90 maco 1.51 rof 1.54 msec/f	Hydo-Quebec	Frame Type
Disconnect Switch	230	Contact Hydo-Quebec	682-PE-0312 ? BCBG-G									4.89 o 5.38 f				2*	1.01 refo 0.71 maco 1.16 rof 1.09 msec/f	Hydo-Quebec	Frame Type
Disconnect Switch	145	Contact Hydo-Quebec	682-PE-0766-C CGCB									10.04 o 15.4 f				2*	-	Hydo-Quebec	Negligible displacements.
Ground Disconnect Switch	765	Contact Hydo-Quebec	682-PE-1011-A ECGS									1.73				2*	1.44	Hydo-Quebec	Candle-like (not frame).
Ground Disconnect Switch	800	Contact Hydo-Quebec	682-PE-5001-A BCVB-G									1.09 o 1.31 f				2*	0.92 refo 1.08 maco 1.18 rof 1.19 msec/f	Hydo-Quebec	Frame Type
Disconnect Switch	245/ 330	Contact Hydo-Quebec	682-PE-5313-A BCVB									1.99 o 2.85 f				5	0.66 refo 0.26 maco 1.39 rof 0.53 msec/f	Hydo-Quebec	Frame Type
Disconnect Switch (SW2)a	230	ABB	Type TTR-8									6f 6o				3f 2o	280	PEER	Values are for "Pole C" & "Post 1" only. SW2 refers to arrangement. See report.
Disconnect Switch (SW2)b	230	ABB	Type TTR-8									6f 6o				2f 2o	280	PEER	Values are for "Pole C" & "Post 1" only. SW2 refers to arrangement. See report.
Disconnect Switch (SW2a)a	230	ABB	Type TTR-8									6f 6o				3f 3o	280	PEER	Values are for "Pole C" & "Post 1" only. SW2a refers to arrangement. See report.
Disconnect Switch (SW2a)b	230	ABB	Type TTR-8									6f 6o				3f 3o	280	PEER	Values are for "Pole C" & "Post 1" only. SW2a refers to arrangement. See report.
Disconnect Switch (SW3)a	230	ABB	Type TTR-8									8.6f 8o				2.2f 2o	110	PEER	Values are for "Pole C" & "Post 1" only. SW3 refers to arrangement. See report.
Disconnect Switch (SW3)b	230	ABB	Type TTR-8									8f 8o				2f 2o	110	PEER	Values are for "Pole C" & "Post 1" only. SW3 refers to arrangement. See report.
Disconnect Switch (SW4)a	230	ABB	Type DR9									3f 2o				4f 4o	380	PEER	Values are for "Pole C" & "Post 1" only. SW4 refers to arrangement. See report.


Arrester 84.9"	180	ABB	Time History	21-Nov-97	1	0.8	IEEE 693-97 Draft High	5		4.3	1st	25	2nd	57.15	Rulon-Frank	Composite
Arrester 88.4"	180	ABB	Time History	21-Nov-97	1	0.8	IEEE 693-97 Draft High	5in		4.3	1st	25	2nd	64.86	Rulon-Frank	Composite
Arrester	475	Siemens	Time History	05-Nov-98	1	0.8	IEEE 693-97 Draft High	13.6	15	2.37	X Axis	2.33	Y Dir	390	Rulon-Frank	Composite
Arrester	420	ABB	Time History	01-Sep-98	0.5	0.4	IEEE 693-97 Draft High	8.3		2				1202	PG+E	Cryed composite insulators structure equipment, Pedestal steel support
Arrester	420	ABB	Time History	01-Sep-98	0.5	0.4	IEEE 693-97 Draft High	9		1.6				1347	PG+E	Cryed composite insulators structure equipment, Pedestal steel support
Arrester	180	ABB	Sine Beat	18-May-00	1	0.8	IEEE 693-97 High	13.92		3.9	Y Axis			76	Rulon-Frank	Transformer (not included in data)
Arrester	180	ABB	Time History	18-May-00	1	0.8	IEEE 693-97 High			3.9	1st			76	Rulon-Frank	Transformer (not included in data)
Arrester	550	Mitsubishi	Time History	01-Oct-96	0.5	0.4	IEEE 693-97 Draft High	2.99	3.31	5.9	X Axis	5.2	Y Axis	15225	Rulon-Frank	Composite bushings, equipment too large to test as a complete unit. Equipment was broken down to two parts with frames attached to simulate the part missing. Short steel leg supports
Arrester	550	Mitsubishi	Sine Beat	01-Oct-96	0.5	0.4	IEEE 693-97 Draft High	2.83	3.43	5.9	X Axis	5.2	Y Axis	15225	Rulon-Frank	Composite bushings, equipment too large to test as a complete unit. Equipment was broken down to two parts with frames attached to simulate the part missing. Short steel leg supports
Arrester	230	ABB								3/o 3/f				629	PEER	Two-post porcelain horizontal-break switch
Arrester	230	ABB								3/o 5/f				629	PEER	Two-post porcelain horizontal-break switch
Arrester	230	ABB								5/o 5.6/f				989	PEER	Three-post porcelain vertical-break pole
Arrester	230	ABB								6/o 6/f				989	PEER	Three-post porcelain vertical-break pole
Arrester	230	ABB								7/o 6.7/f				450	PEER	Three-post composite vertical-break post
Arrester	230	ABB								8/o 8/f				450	PEER	Three-post composite vertical-break post
Arrester			Dynamic Analysis	14-Jan-97	0.2		IEEE 693-84	8		1.24	X Axis				PG+E	Welded to Pad
Arrester	500		Dynamic Analysis	04-Feb-93	0.5		IEEE 693/PG&E	11.84		1.17	1st Res Freq		5		PG+E	Square Tube 16 x 16 x 5/16" Rubber pads at foundation connections
Arrester	138	ABB	Time History	24-Sep-97	0.5	0.4	IEEE 693-97 Draft High	0.98		8.6	1st	10.9	2nd	1900	Rulon-Frank	ST 16x16x.375
Arrester	138	ABB	Sine Beat	24-Sep-97	0.6	0.4	IEEE 693-97 Draft High	0.47		8.6	1st	10.9	2nd	1900	Rulon-Frank	ST 16x16x.375

APPENDIX B. SHOP DRAWINGS OF GENERIC EQUIPMENT SPECIMENS


EQUIPMENT 1




UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES FRACTIONS ARE			CONTRACT NO.		UCSD University of California, San Diego		
FRACTIONS DECIMALS ANGLES 1/8 1/16 1/32 1/4 1/8 1/16 1/32 1/2 1/4 1/8 1/16 1/32 90 45 30			APPROVALS		DATE		HSS 7x5x3/16 BEAM Side View
DRAWN SIGNED CHECKED NOTED					5/20/1999 5/20/1999		
MATERIAL			TYPE		SPT DWG NO.		BY
FINISH			ESUDO		A		
DO NOT SCALE DRAWING					SCALE IN		CAD FILE
							SHEET 1 OF 1





EQUIPMENT 2




UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DECIMALS ARE			CONTRACT NO.		UCSD University of California, San Diego		
DIMENSIONS ARE IN INCHES DECIMALS ARE			APPROVALS		DATE		
DESIGNED BY	CHECKED BY	APPROVED BY	DESIGNED BY	DATE	HSS 3-1/2x2-1/2x1/4 BEAM		
DATE	DATE	DATE	DATE	DATE	Side View		
MATERIAL			GROUP		SHEET NO.	OF	
MAKE			SIZE		A		
DO NOT SCALE DRAWING					SCALE IN	CAD FILE	SHEET OF








EQUIPMENT 3



NOTE:
This box is identical to
the one in drawing
HSS 12x6x3/16 BEAM

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES FOR DETAILS ARE			CONTRACT NO.		UCSD University of California, San Diego		
REVISIONS			APPROVALS		DATE		
NO.	DESCRIPTION	DATE	BY		5/20/1999		
			CHECKED		5/20/1999		
DRAWN			PROJECT		SHEET NO.		
DATE			ISSUE		REV.		
DO NOT SCALE DRAWING					SCALE 1" = 4" CAB. REP. SHEET 1 OF 1		



EQUIPMENT 4

